

Evacuation instructions for people with impaired mobility and wheelchair users in BLOKÆDEN and adjacent buildings

These instructions are given to wheelchair users and others who may benefit from knowing them (typically employees near wheelchair users) upon employment at the university.

In case of an evacuation, use of the lifts is not permitted. This can be particularly challenging for people with impaired mobility and wheelchair users.


In such situations, it must be ensured that the people concerned are placed in a relatively safe zone. This may, for example, be behind a fire door, on a balcony or anywhere else that is considered safe in the situation.

We encourage you to get an overview of the building in which you work in order to familiarize yourself with the safe zones nearby.

As a non-impaired person, it is important that you do not remain standing by the wheelchair user. Instead, go to the assembly point and notify the highest authority present, so that the wheelchair user can be helped.

Here are a few examples of what a fire door might look like:

The red stripe, which is most often found in older doors, means at least 30 minutes of protection.



In some doors there is a sign BD-30, as here in the picture. BD means "Fire Door" and 30 stands for the number of minutes - so can keep the fire away for at least 30 minutes.



A BD-60 door keeps the fire away for at least 60 minutes.



This allows the emergency services to come to the aid of the disabled person.

The above has been prepared by ECOS AMO Campus and BIO LAMU

Lone Ottosen and Else Vihlborg Staalsen